

## Blecharczyk, Jeffrey

---

**From:** Friend, Ashley C <ashley.friend@eversource.com>  
**Sent:** Tuesday, March 7, 2023 12:16 PM  
**To:** Conor Madison; Blecharczyk, Jeffrey; Edwards, Vincent  
**Cc:** deborah.zartagier (gza.com)  
**Subject:** RE: Eversource site walk 2/28/23

**EXTERNAL: Do not open attachments or click on links unless you recognize and trust the sender.**

---

Hi Jeff,

The gravel fill used within the CMP meets NHDOT 304.4 sieve size standards. For structures in uplands, the exterior of the CMP is padded with either 8" of flowable fill or 10" of NHDOT 304.4 mix. For structures in wetlands, we don't put any material around the outside of the CMP.

Let me know if you have any other questions.

Thanks,  
Ashley

**ASHLEY FRIEND**

Specialist - Licensing & Permitting

**EVERSOURCE**

13 Legends Drive, Hooksett, NH 03106

603-634-2992

[Ashley.Friend@Eversource.com](mailto:Ashley.Friend@Eversource.com)

---

**From:** Conor Madison <Conor.Madison@gza.com>

**Sent:** Tuesday, March 7, 2023 9:38 AM

**To:** Blecharczyk, Jeffrey <JEFFREY.D.BLECHARCZYK@des.nh.gov>; Edwards, Vincent <vincent.edwards@eversource.com>

**Cc:** Friend, Ashley C <ashley.friend@eversource.com>; deborah.zartagier ([gza.com](mailto:gza.com)) <deborah.zartagier@gza.com>

**Subject:** RE: Eversource site walk 2/28/23

**EVERSOURCE IT NOTICE – EXTERNAL EMAIL SENDER \*\*\*\* Don't be quick to click! \*\*\*\***

Do not click on links or attachments if sender is unknown or if the email is unexpected from someone you know, and never provide a user ID or password. Report suspicious emails by selecting 'Report Phish' or forwarding to [SPAMFEEDBACK@EVERSOURCE.COM](mailto:SPAMFEEDBACK@EVERSOURCE.COM) for analysis by our cyber security team.

---

Hi Jeff,

Apologies for the delay as I just returned back to work this morning. Thanks again for coming out to the site on Tuesday, it was nice to finally meet you after all our phone calls.

Vince – I believe this question is more focused on your expertise. Jeff is asking about the specific fill used within the CMP and which specs they meet.

Thank you,

Conor

Conor Madison, CPESC, CESSWI

Project Manager

GZA | 5 Commerce Park North | Bedford, NH 03110

o: 603.232.8784 | c: 207.331.6629 | [conor.madison@gza.com](mailto:conor.madison@gza.com) | [www.gza.com](http://www.gza.com) | [LinkedIn](#)

GEOTECHNICAL | ENVIRONMENTAL | ECOLOGICAL | WATER | CONSTRUCTION MANAGEMENT

Known for excellence. Built on trust.

---

**From:** Blecharczyk, Jeffrey <[JEFFREY.D.BLECHARCZYK@des.nh.gov](mailto:JEFFREY.D.BLECHARCZYK@des.nh.gov)>

**Sent:** Wednesday, March 1, 2023 4:28 PM

**To:** Conor Madison <[Conor.Madison@gza.com](mailto:Conor.Madison@gza.com)>

**Subject:** [EXTERNAL] Eversource site walk 2/28/23

Hi Conor,

Thanks, again for assisting with the site walk this past Tuesday. I do have a follow up question that hopefully you can answer, or maybe Vince can. In my notes I wrote the fill used in the corrugated pipes met road fill specs.

Just want to make sure I have the right soil fill specs, in conjunction with occasional use of flow fill.

Thanks

Jeffrey Blecharczyk  
Compliance Supervisor, Wetlands Bureau  
Land Resources Management  
PO Box 95  
Concord NH 03302-0095  
PHONE: (603)271-4061  
FAX: (603)271-6588  
EMAIL: [jeffrey.blecharczyk@des.nh.gov](mailto:jeffrey.blecharczyk@des.nh.gov)

 [Follow us on Twitter!](#)

 [Like us on Facebook!](#)

**We value your feedback. Please consider completing a 3-minute [customer satisfaction survey](#).**

---

*This electronic message is intended to be viewed only by the individual or entity to which it is addressed and may contain privileged and/or confidential information intended for the exclusive use of the addressee(s). If you are not the intended recipient, please be aware that any disclosure, printing, copying, distribution or use of this information is prohibited. If you have received this message in error, please notify the sender immediately and destroy this message and its attachments from your system.*

---

For information about GZA GeoEnvironmental, Inc. and its services, please visit our website at [www.gza.com](http://www.gza.com).

---

This electronic message contains information from Eversource Energy or its affiliates that may be confidential, proprietary or otherwise protected from disclosure. The information is intended to be used solely by the recipient(s) named. Any views or opinions expressed in this message are not necessarily those of Eversource Energy or its affiliates. Any disclosure, copying or distribution of this message or the taking of any action based on its contents, other than by the intended recipient for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please

notify the sender immediately and delete it from your system. Email transmission cannot be guaranteed to be error-free or secure or free from viruses, and Eversource Energy disclaims all liability for any resulting damage, errors, or omissions.