



Rhode Island Energy™
a PPL company



PPL's Dynamic Line Ratings (DLR) System


6/18/2025

ISO-NE PAC Meeting

Eric Rosenberger

Principal Engineer – T&S Standards

Where we operate.




Delivering reliable power to **3.5 million customers**
across **20,600 square miles.**



Background

Original Dynamic Line Ratings Use Case

- 2020 PJM Market Efficiency Case
- \$23.5 Million in annual congestion costs projected in 2025
- Harwood to Susquehanna #1 & #2 | 230 kV | ACSS |
- Juniata to Cumberland | 230 kV | ACSR |



2020/21 RTEP Market Efficiency Window Eligible Energy Market Congestion Drivers* (Posted 03-05-2021)				ME Base Case (Annual Congestion \$million)		ME Base Case (Hours Binding)	
FG#	Constraint	FROM AREA	TO AREA	2025 Simulated Year	2028 Simulated Year	2025 Simulated Year	2028 Simulated Year
ME-1	Kammer North to Natrium 138 kV	AEP	AEP	\$ 2.02	\$ 6.56	69	167
ME-3	Junction to French's Mill 138 kV	APS	APS	\$ 9.18	\$ 11.97	276	301
ME-4	Yukon to AA2-161 Tap 138 kV	APS	APS	\$ 4.36	\$ 5.16	1742	1958
ME-5	Charlottesville to Proffit Rd Del Pt 230 kV	DOM	DOM	\$ 3.76	\$ 4.96	121	124
ME-6	Plymouth Meeting to Whitpain 230 kV	PECO	PECO	\$ 3.33	\$ 4.09	111	101
ME-7	Cumberland to Juniata 230 kV***	PLGRP	PLGRP	\$ 9.00	\$ 6.61	213	179
ME-8	Harwood to Susquehanna 230 kV***	PLGRP	PLGRP	\$ 14.49	\$ 8.69	830	501

Solutions Considered



Reconductor



Rebuild



Dynamic Line Rating



Time to Implement	2 – 3 Years	3 – 5 Years	~1 Year
Downtime	Extended Outages	Extended Outages	No Outages
Cost	\$0.5 M per mile	\$2 - 3 M per mile	< \$1 M
Est Capacity Benefit	+ 34%	+ 106%	+ 10 – 30%

What is DLR?



DLR is a system of installed line sensors used to measure conductor and environmental real-time data to determine a real-time rating instead of assumed condition values

Existing Line Ratings

Assumes:

- Wind speed
- Ambient temperature
- Solar radiation

2 Seasons (Summer & Winter) (Planning)

Ambient Adjusted (Operations)

- Conservatively calculates ratings

Dynamic Line Ratings

Measures:

- Wind speed
- Ambient temperature
- Conductor temperature
- Conductor sag

Provides Accurate Real-Time Ratings


Allows for Forecasted Rating

- Measures Conductor Health

Target Span Identification



1 Critical Span Distribution From DLR Simulation



2 Required Span Selection Rules

- Orientation between spans changes more than 15°
 - → To capture variability in wind direction
- Distance is greater than 10 km
- Conductor or number of sub-conductor change
- Span safety concerns
- Utility span data identifies high risk span(s)

3 Final Span Selection



4 Installation

- One phase per identified span
- Sensor mounted 5 – 10% of the total span length from either tower
- Live Line Installation Via Helicopter and from ground
- Mounting procedure is 5 - 10 minutes per sensor




SUSQ-HARW In-Service Results



SUSQ-HARW #1 & #2 (ACSS) Fully in-service in December 2022:

- ~17% Average Normal Rating Increase (2023)
- ~16.5% Average Emergency Rating Increase (2023)
- Congestion drop from ~\$2 million to ~\$0 for winter 2021-22 to 2022-23




JUNI-CUMB In-Service Results



JUNI-CUMB (ACSR) Fully in-service in October 2022:

- ~17% Average Normal Rating Increase (2023)
- ~8.5% Average Emergency Rating Increase (2023)
- Congestion drop from >\$60 million to ~\$1.6 Million for winter 2021-22 to 2022-23




Real Time DLR In Action

December 2022 Polar Vortex



DLR Real Time vs. AAR Ratings: JUNI-CUMB


Real Time DLR Ratings vs AAR



12/16/2022 8:44:14 PM
Normal Ambient Adjusted Rating Emergency Ambient Adjusted Rating TC 230 9005


DLR Real Time vs. AAR Ratings: SUSQ-HARW 1

Real Time DLR Ratings vs AAR



12/10/2022 6:53:28 AM 27.69 days 1/6/2023 11:22:14 PM
Normal Ambient Adjusted Rating Emergency Ambient Adjusted Rating CE 230 35085 DLR DLR DLR

Ratings Data Flow





NERC Standards Considerations

CIP Standards:

CIP-002: System Categorization

CIP-005: Electronic Security Perimeters


CIP-006: Physical Security

PRC-023 – Relay Loadability

FAC-008 – Ratings Methodology



FAC-008 Operations Considerations




TMS Operator Display



Current line loading


Current real-time ratings

Rating Zone if DLR goes down




Various DLR indication, validation, and quality points for situational awareness

DLR Implementation Timeline



Original Implementation with PPL's EMS and PJM





Application Plan for RIE

- DLR installed and operating in a Development environment for the following RIE lines:
 - 1870, 1870N, 1870S and 1870S_2
 - H17, H17_S
 - 328
- FERC 881 upgrades needed within ISO-NE before these lines can be operated to DLR in real time and day ahead markets
- After FERC 881 upgrades are completed, RIE will evaluate integrating DLRs with ISO-NE Operations.



Questions?




Photo of some of the DLR team members: from left, Andrew Henry, Horst Lehmann, Bill Elko, and Eric Rosenberger

