



Brent Oberlin
Director, Transmission Planning

September 22, 2021

Ms. Meiyun Li
Eversource Energy
780 North Commercial Street
Manchester, NH 03101

Subject: Line G192 Conductor Replacement Project - Proposed Plan Application (PPA) – ES-21-T50

Dear Ms. Li,

This letter is to inform you that, pursuant to review under Section I.3.9 of the ISO Tariff, no significant adverse effect has been identified with regard to the following PPAs:

ES-21-T50 – Transmission application from Eversource Energy (ES) for the replacement of 1.29 miles for Line G192 from structure 2 to structure 17 with 795 ACSR 16/7 conductor between Bridge Street substation in Nashua, NH and Power Street substation in Hudson, NH. The proposed in-service date is December 2021. The Reliability Committee (RC) reviewed the materials presented in support of the proposed project and did not identify a significant adverse effect on the reliability or operating characteristics of its transmission facilities, the transmission facilities of another Transmission Owner or the system of any other Market Participant.

Having given due consideration to the RC review, ISO New England has determined that implementation of the plan will not have a significant adverse effect upon the reliability or operating characteristics of the Transmission Owner's transmission facilities, the transmission facilities of another Transmission Owner, or the system of a Market Participant. A determination under Section I.3.9 of the ISO Tariff is limited to a review of the reliability impacts of a proposed project as submitted by Participants and does not constitute an approval of a proposed project under any other provisions of the ISO Tariff.

Sincerely,

/s/ Brent Oberlin

Brent Oberlin
Director, Transmission Planning

cc: Proposed Plan Applications