

Forward Capacity Auction 11 Transmission Transfer Capabilities & Capacity Zone Development

Planning Advisory Committee



Al McBride

DIRECTOR, TRANSMISSION STRATEGY & SERVICES



Topics

- Forward Capacity Auction 11 (FCA-11, Capacity Commitment Period 2020-2021) Zone Formation
- Transfer Limit Summary



Background

- In November 2015, in preparation for the Capacity Zone formation process for FCA-11, the Planning Advisory Committee engaged in comprehensive discussion of the zone formation process and the expected direction of zone preparations for FCA-11
- Four presentations made at November 2015 PAC relative to capacity market
 - Historical Development [link to presentation](#)
 - Current Process [link to presentation](#)
 - Review of Determination for FCA 10 [link to presentation](#)
 - New England Power System in 2020 [link to presentation](#)
- The Scope of Work for the FCA-11 transfer capability and zone formation process was presented at the January 2016 PAC
http://www.iso-ne.com/static-assets/documents/2016/01/a9_fca_11_zonal_interfaces.pdf



FCA-11 CAPACITY ZONE FORMATION

Proposed Potential Zonal Construct for FCA-11

- The potential Capacity Zone construct for FCA-11 is unchanged from the proposed construct in FCA-10
 - Newly certified transmission caused no significant change in the boundaries associated with the transmission system's ability to reliably transfer energy in the planning horizon
 - No significant change in appropriate zonal boundaries due to resource retirements or resource additions in FCA-10




Transmission Transfer Capabilities

- Capacity Zone boundary transfer capabilities
 - Further details are provided later in this presentation

| FCA-10 Transfer Capabilities (MW) | | FCA-11 Transfer Capabilities (MW) | |
|------------------------------------|-------|------------------------------------|-------|
| Southeast New England Import N-1 | 5,700 | Southeast New England Import N-1 | 5,700 |
| Southeast New England Import N-1-1 | 4,600 | Southeast New England Import N-1-1 | 4,600 |
| Connecticut Import N-1 | 2,950 | Connecticut Import N-1 | 3,400 |
| Connecticut Import N-1-1 | 1,750 | Connecticut Import N-1-1 | 2,200 |
| North-South N-1 | 2,675 | North-South N-1 | 2,725 |



Proposed Potential Zonal Construct for FCA-11



Note that zones are modeled in the FCA only if the objective criteria in Market Rule 1, Section 12 is triggered

TRANSFER LIMIT SUMMARY

North-South Interface: Transfer Capability - Updated

- The Northern New England-Scobie + 394 stability transfer limit has been updated to include the Greater Boston upgrades

https://smd.iso-ne.com/operations-services/ceii/pac/2016/03/a2_fca11_zonal_boundary_northern_new_england_scobie_394_transfer_limits.pdf

- With NNE-Scobie + 394 at the margined limit of 3,200 MW, the following elements are simultaneously at 100% of their Long Term Emergency (LTE) ratings, post contingency.....
 - 230 kV Line O215 from North Litchfield-Tewksbury
 - 230/115 kV Transformer T2 at Tewksbury
- ...at the following level of North-South Transfer Capability

North-South Transfer Capability (N-1)

2,725 MW¹

1. The FCA-10 value for the North-South transfer capability was 2,675 MW



Transfer Capability Updates Due to Connecticut Upgrades

- The Transmission Certifications for FCA-11 were presented at the January Reliability Committee

<http://www.iso-ne.com/committees/reliability/reliability-committee/?eventId=128730>

- It was noted at the January Planning Advisory Committee (PAC) that not all of the components of the Greater Hartford/Central Connecticut and Southwest Connecticut projects were included in the Network Model for FCA-11

http://www.iso-ne.com/static-assets/documents/2016/01/a9_fca_11_zonal_interfaces.pdf

- At the January PAC, stakeholders asked if there was any benefit to the Connecticut import capability from those portions of the projects that were certified



Transfer Capability Updates Due to Connecticut Upgrades, continued

- The Proposed Plan Application analyses for the Greater Hartford/Central Connecticut project included evaluations of the transfer capabilities after the addition of the project
https://smd.iso-ne.com/operations-services/ceii/rc/2015/03/a3_1_swct_ghcc_lvl3_ppa_ghcc_sis.pdf
- The ISO has reviewed the projects that were certified for FCA-11 and has found that sufficient components of the Greater Hartford/Central Connecticut project have accepted certifications to support the adoption of the post-project transfer limits

| | |
|---|-----------------|
| Connecticut Import Transfer Capability (N-1) | 3,400 MW |
| Connecticut Import Transfer Capability (N-1-1) | 2,200 MW |



FCA-11 Base Internal Interface Limits

| Single-Value, Summer Peak, ¹ Non-Firm, Transmission Interface Limits for Use in Subarea Transportation Models | | | | | | | | | | |
|--|------|------|-------------------|-------------------|-------------------|------|------|------|------|------|
| Interface | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
| Orrington South Export | 1325 | 1325 | 1325 | 1325 | 1325 | 1325 | 1325 | 1325 | 1325 | 1325 |
| Surowiec South | 1500 | 1500 | 1500 | 1500 | 1500 | 1500 | 1500 | 1500 | 1500 | 1500 |
| Maine-New Hampshire | 1900 | 1900 | 1900 | 1900 | 1900 | 1900 | 1900 | 1900 | 1900 | 1900 |
| Northern New England-Scobie + 394 | 3100 | 3100 | 3100 | 3100 | 3200 ^c | 3200 | 3200 | 3200 | 3200 | 3200 |
| North-South | 2100 | 2100 | 2100 | 2675 ^a | 2725 ^c | 2725 | 2725 | 2725 | 2725 | 2725 |
| East-West | 3500 | 3500 | 3500 | 3500 | 3500 | 3500 | 3500 | 3500 | 3500 | 3500 |
| West-East | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 |
| Boston Import (N-1) | 4850 | 4850 | 4850 | 5700 ^a | 5700 | 5700 | 5700 | 5700 | 5700 | 5700 |
| Boston Import (N-1-1) | 4175 | 4175 | 4175 | 4600 ^a | 4600 | 4600 | 4600 | 4600 | 4600 | 4600 |
| SEMA/RI Export | 3400 | 3400 | 3400 | 3400 | 3400 | 3400 | 3400 | 3400 | 3400 | 3400 |
| SEMA/RI Import (N-1) | - | - | 1280 ^b | 1280 | 1280 | 1280 | 1280 | 1280 | 1280 | 1280 |
| SEMA/RI Import (N-1-1) | - | - | 720 ^b | 720 | 720 | 720 | 720 | 720 | 720 | 720 |
| Southeast New England Import (N-1) | - | - | - | 5700 ^a | 5700 | 5700 | 5700 | 5700 | 5700 | 5700 |
| Southeast New England Import (N-1-1) | - | - | - | 4600 ^a | 4600 | 4600 | 4600 | 4600 | 4600 | 4600 |
| Connecticut Import (N-1) | 2950 | 2950 | 2950 | 2950 | 3400 ^d | 3400 | 3400 | 3400 | 3400 | 3400 |
| Connecticut Import (N-1-1) | 1750 | 1750 | 1750 | 1750 | 2200 ^d | 2200 | 2200 | 2200 | 2200 | 2200 |
| SW Connecticut Import (N-1) | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 |
| SW Connecticut Import (N-1-1) | 2300 | 2300 | 2300 | 2300 | 2300 | 2300 | 2300 | 2300 | 2300 | 2300 |

Notes are discussed on the following pages



Base Internal Interface Limits, continued ...

Notes to table on Slide 11

1. Limits are for the summer period, except where noted to be winter
 - The limits may not include possible simultaneous impacts, and should not be considered as “firm”
 - For the years within the FCM horizon (CCP 2020-21 and sooner), only accepted certified transmission projects are included when identifying transfer limits
 - Accepted certified transmission projects presented to the Reliability Committee at their January 20, 2016 meeting
 - For the years beyond the FCM horizon (June 1, 2021 and later), proposed plan approved transmission upgrades are included according to their expected in-service dates

Base Internal Interface Limits, continued ...

Notes to table on Slide 11

- a) Greater Boston Upgrades
 - The certification of this project to be in service by June 2019 has been accepted by ISO New England

- b) In response to the Brayton Point retirement, the following Rhode Island area facilities are now planned to be upgraded (and are certified to be in service by the start of CCP-9)
 - The V148N 115 kV line from Woonsocket to Washington
 - West Farnum 345/115 kV autotransformer (already in service)
 - Kent County 345/115 kV autotransformer (already in service)

- c) Northern New England Scobie + 394
 - Stability limit has been updated

- d) Greater Hartford/Central Connecticut Upgrades
 - The certification of a significant portion of this project to be in service by June 2019 has been accepted by ISO New England



EXTERNAL INTERFACES

FCA-11 Transmission Upgrade Certifications

- As previously noted, not all of the components of the Greater Hartford/Central Connecticut and Southwest Connecticut projects were included in the Network Model for FCA-11
 - In particular, elements of the Southwest Connecticut project that would be relevant to the transfer capability evaluation for Cross Sound Cable were not yet certified
- When the certifications of these projects are accepted for inclusion in the FCM Network Model, the Cross Sound Cable (CSC) capacity import capability will be re-evaluated
 - There is no change in this interface transfer capabilities for FCA-11



FCA-11 External Interface Import Capability

Single-Value, Summer Peak,¹ Non-Firm, Transmission Interface Limits for Use in Subarea Transportation Models

| Interface | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|---|------|------|------|------|------|------|------|------|------|------|
| New Brunswick-New England (energy import capability) ² | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 |
| New Brunswick-New England (capacity import capability) | 700 | 700 | 700 | 700 | 700 | 700 | 700 | 700 | 700 | 700 |
| HQ-New England (Highgate) (energy import capability) ³ | 217 | 217 | 217 | 217 | 217 | 217 | 217 | 217 | 217 | 217 |
| HQ-New England (Highgate) (capacity import capability) | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 |
| HQ-New England (Phase II) (energy import capability) ⁴ | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 |
| HQ-New England (Phase II) (capacity import capability) | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 |
| Cross-Sound Cable (CSC) (energy import capability) ⁵ | 330 | 330 | 330 | 330 | 330 | 330 | 330 | 330 | 330 | 330 |
| Cross-Sound Cable (CSC) (capacity import capability) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| New York-New England (energy transfer capability) ⁶ | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 |
| New York-New England (capacity transfer capability) | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 |



These values may be updated based on updated transfer analysis after the Southwest Connecticut upgrades

Notes are discussed on the following pages



External Interface Import Capability

Notes to table on Slide 16

1. Limits are for the summer period
 - The limits may not include possible simultaneous impacts, and should not be considered as “firm” (the bases for these limits are subject to more detailed review in the future)
2. The electrical limit of the New Brunswick-New England (NB-NE) Tie is 1,000 MW
 - When adjusted for the ability to deliver capacity to the greater New England Control area, the NB-NE transfer capability is 700 MW
 - This is because of downstream constraints; in particular Orrington South
3. The capability for the Highgate facility is listed at the New England AC side of the Highgate terminal



External Interface Import Capability, continued ...

Notes to table on Slide 16

4. The Hydro-Quebec Phase II interconnection is a DC tie with equipment ratings of 2,000 MW. Due to the need to protect for the loss of this line at full import level in the PJM and NY Control Areas' systems, ISO-NE has assumed its transfer capability for capacity and reliability calculation purposes to be 1,400 MW
 - This assumption is based on the results of loss-of-source analyses conducted by PJM and NY
5. Import capability on the Cross Sound Cable is dependent on the level of local generation
6. New York interface limits
 - These are without CSC and with the Northport Norwalk Cable at 0 MW flow
 - Simultaneously importing into NE and SWCT or CT can lower the NY-NE capability (very rough decrease = 200 MW)



Next Steps

- Present final potential Capacity Zone boundary construct for FCA-11
 - March 2016 Reliability Committee



Questions



APPENDIX

METHODOLOGY FOR MODELING CAPACITY ZONES IN FCM



Developing Zonal Boundaries for the FCM

- Included in Attachment K of the Open Access Transmission Tariff:
 - Annual Assessment of Transmission Transfer Capability
 - Each year, the ISO shall issue the results of the annual assessment of transmission transfer capability, conducted pursuant to applicable NERC, NPCC and ISO New England standards and criteria and the identification of potential future transmission system weaknesses and limiting facilities that could impact the transmission system's ability to reliably transfer energy in the planning horizon.
 - Each annual assessment will identify those portions of the New England system, along with the associated interface boundaries, that should be considered in the assessment of Capacity Zones to be modeled in the Forward Capacity Market pursuant to ISO Tariff Section III.12.

Zone Formation: A Two Step Process

| Step ONE | Step TWO |
|--|---|
| <p>Identify the potential zonal boundaries and associated transfer limits to be tested for modeling in the FCM</p> | <p>Use objective criteria to determine whether or not the zone should be modeled for the Capacity Commitment Period</p> |
| | <p>Import-constrained zone Trigger to model the zone is based on the quantity of surplus resources in the zone above the zonal requirement</p> <p>Export-constrained zone: Trigger to model the zone is based on the quantity of existing and proposed new resources compared with the maximum capacity capability in the zone</p> <p>Zones that are neither import- or export-constrained are collapsed into the rest-of-pool zone</p> |

Zonal Modeling Timeline

Preview
Boundary
Expectations
for Upcoming
FCA Cycle

Pursuant To Attachment K:

- Conduct Transfer Analysis
- Identify Zones & Boundaries to be evaluated in FCM preparation
- Discuss with PAC
- Present to RC

File New
Capacity
Zone
Boundary at
FERC – if
proposed

Pursuant To Tariff Section III.12:

- Calculate whether the zones identified pursuant to Attachment K should be modeled using the objective criteria
- ICR, LSR & Tie Benefits calculations
- Discuss with PSPC
- Present to RC for vote

Retirement
requests that are
received in this
time-frame would
be captured in the
zone-modeling
calculation

SOI

File Capacity
Zones and
Requirements
at FERC

FCA



**This illustration reflects potential timeline change proposals associated with the Retirement Reforms project.*