

Morning Tom,

Thank you for the information and apologize for the delay in issuing the permit. We met onsite a couple weeks ago and you are good to proceed. Des will be issuing the permit shortly. Also, we decided that no culvert is needed. The 20' min. paved apron should be at existing grade with any drainage flowing over the apron at the low point before climbing to the existing connector. The approach shall be perpendicular to both NH 25 and the existing connector. Do not hesitate to contact us if you have any questions or comments.

Thank you,

Chris

## Chris Turgeon, P.E.

Assistant District Engineer NHDOT District 2 Maintenance Exit 16, Interstate 89 8 Eastman Hill Road, Enfield, NH 03748

Ph: (603) 448-2654 Cell: (603) 252-6415 Fax: (603) 448-2059

Christopher.Turgeon@dot.nh.gov

From: Tom Babbit < bab1234@netzero.net > Sent: Friday, April 24, 2020 12:57 PM

**To:** Turgeon, Christopher < <a href="mailto:Christopher.Turgeon@dot.nh.gov">Christopher.Turgeon@dot.nh.gov</a>>

Cc: Savage, Clinton < Clinton.Savage@dncr.nh.gov >

**Subject:** Request to perform work on DOT ATV crossing for grant in aid.

**EXTERNAL:** Do not open attachments or click on links unless you recognize and trust the sender.

Chris,

Please see attached request for our club to install the ATV crossing at scenic view campground, I know this needs a culvert since there is a ditch we are crossing our plan is to install a 12 inch unless a larger diameter is required.

Review and return at your convenience.

Regards

Tom Babbit

Mount Moosilaukee ATV Club

