

September 8, 2022

Ms. Emily Laine
Chair, NEPOOL Reliability Committee
ISO New England, Inc.
One Sullivan Road
Holyoke, MA 01040-2841

Dear Ms. Laine,

In accordance with Schedule 12C of the ISO New England (“ISO-NE”) Transmission, Markets & Services Tariff (“ISO-NE Tariff”), Eversource Energy Service Company (“Eversource”) hereby submits the attached Transmission Cost Allocation (“TCA”) application(s) reporting cost support information associated with the construction, retirement, or modification to facilities rated 69 kV and above that qualify as regional Pool Transmission Facilities (“PTF”) for the following Eversource project:

**ES-22-TCA-04 NH 2029 Preferred Solution – Central / 115-kV Huckins Hill
Synchronous Condenser Project**

Eversource is requesting that ISO-NE submit this TCA to the NEPOOL Reliability Committee for review, in accordance with ISO-NE Planning Procedure No. 4 (“PP-4”).

If you have any questions, I can be reached via the information listed above.

Sincerely,

Steven J. Allen

Steven J. Allen

cc: M. Drzewianowski

Attachment B
TCA Application Form

1. Applicant: Application #: ES-22-TCA-04 Date: Sep-22
 Contact Name: Steven J. Allen
 Company Name: Eversource Energy Service Company
 Address 1: 56 Prospect Street
 Address 2: _____
 City, State, Zip: Hartford, CT 06103 RSP Project ID # or Asset Condition ID # 1879
 Contact Phone #: 860-728-4536 Is Project related to CIP-14
 Email Address: steven.allen@eversource.com Yes No

2. Project Description: In Service Date: Dec-23

a. **High Level Project Details:**

Project Name (If no formal name, then Substation Upgrade, Line Upgrade, etc. are acceptable):

NH 2029 Solution Central - 115-kV Huckins Hill Synchronous Condenser Project

Project Location (State only):

State:

NH

County:

Grafton

b. Summary of PTF-related work for Project:

Install a +50/-25 MVAR Synchronous Condenser at Huckins Hill 115-kV substation with a 115-kV breaker.

Final project cost details will be known following closeout of all project work orders.

c. Summary of Non-PTF-related work for Project:

3. Was a transmission Proposed Plan Application required for this work? Yes No PPA Number: ES-22-T28
 4. Has a transmission Proposed Plan Application been approved? Yes No N/A Approval Date: June 15, 2022
 If yes, attach a copy and reference Proposed Plan Application # and approval date. (Please check only one)

Need For Project:

5. Need Based On (Check all Categories that apply):

- a. Reliability
- b. Economic
- c. Service to new load
- d. New generator interconnection

Generator Proposed Plan Application Number _____

Generator Proposed Plan Application Date _____

(Attach copy of cover letter & Generator Proposed Plan Application)

- e. Public Policy Transmission Upgrade (PPTU)
- f. Market Efficiency Transmission Upgrade (METU)
- g. Asset Condition
- h. Other (specify in line 6)

6. Provide a narrative description of the need for this Project.
(Include available documentation relative to the need for this Project.)

The ISO-NE New Hampshire 2029 Solutions Study referenced the needs to upgrade the Central New Hampshire area transmission system. The objective of the Solutions Study was to investigate transmission solutions to remedy the NH study area time-sensitive criteria violations in accordance with applicable NERC, NPCC, and ISO standards and criteria.

This preferred solution is in the NH 2029 Solutions Study that was developed in coordination with ISO-NE as detailed in the final NH 2029 Solutions Study, posted on the ISO-NE’s external website on May 27, 2021.

The final Solution Study report can be found posted at the following link:
<https://www.iso-ne.com/system-planning/key-study-areas/vt-nh/>

Cost of Project:

7. Total Project Cost (\$M) equals PTF + Non-PTF + all other Project Costs:	<u>\$33.449</u>
8. Total Proposed PTF Costs	
a. Total Proposed PTF Cost of this Project (\$M):	<u>\$33.449</u>
b. Requested Pool-Supported PTF Costs associated with this Project (\$M):	<u>\$33.449</u>
c. Breakdown of Requested Pool-Supported PTF Cost associated with this Project (\$M): (Consistent with Table 1 and Appendix D of this Procedure)	
Material	<u>\$12.612</u>
Labor	<u>\$12.080</u>
ROW	<u>\$0.000</u>
Engineering/Permitting/Indirects	<u>\$2.775</u>
Escalation	<u>\$0.838</u>
AFUDC (or equivalent)	<u>\$1.681</u>
Contingency	<u>\$3.463</u>
d. Generator Supported PTF Costs* (\$M):	<u>\$0.000</u>
If the costs in 8.b. plus 8.d. do not equal the total proposed PTF cost (8.a) explain and indicate who is responsible for the remaining costs.	
9. Total Proposed Non-PTF Cost of this Project (\$M):	<u>\$0.000</u>
10. Proposed PTF Costs (\$M) introduced as a result of local, state or other regulatory/legislative requirements, including costs identified pursuant to Section 1.6.3 of this PP-4.	<u>\$0.000</u>
a. Description of Proposed PTF Cost introduced as a result of local, state or other regulatory/legislative requirements as defined in question 8 above.	
11. All other Project Costs not captured in PTF Costs (8) or Non-PTF Costs (9) (\$M) associated with this Project:	<u>\$0.000</u>

12. Total PTF Cost based on: (check one)

Actual Costs

OR

Estimated Costs*

13. Valuation Year(s) of dollar amounts submitted above: 2022

14. If applicable, explain how the cost of common facilities were allocated between PTF and Non-PTF.

15. Does this Project result in a change of existing Non-PTF facilities to PTF?

Yes

No

16. Describe the major transmission alternatives, and their costs consistent with the breakdown provided in item 7 of this Application, that were considered. Provided an explanation why the preferred alternative was selected.
(Include available documentation relative to the major transmission alternatives analysis and selection.)

Alternative:

Construct a 10-mile 115-kV line between Pemigewasset and Webster substations and install one 115-kV breaker at Webster and four 115-kV breakers at Pemigewasset. This Alternative is not the Preferred Solution as it involves greater siting concerns and challenges.

Preferred:

Install a +50/-25 MVAR Synchronous Condenser at Huckins Hill 115-kV substation with a 115-kV breaker. This alternative performs better under contingency analysis, provides much-needed voltage regulation in the area, and has minimal siting concerns, therefore, this is the Preferred Solution.

17. Has state and local siting been completed? If yes, explain the siting process and any provisions that were made during siting, provide docket or siting reference numbers. If no, then explain when siting is expected to be completed and any provisions that have been agreed to.

No unusual Siting required.

* Pool-Supported PTF costs were determined pursuant to Schedule 11 of Section II of the Tariff.

PROJECT COST ESTIMATE & SCHEDULE SHEET

Transmission Owner: Public Service Company of New Hampshire

RSP Project #: 1879

Project Name: NH 2029 Solution Central - 115-kV Huckins Hill Sync Condenser

Date: Sep-22

1. Project Scope Summary


Install one +50/-25 MVAR synchronous condenser and one 115-kV breaker at the Huckins Hill 115-kV substation.

2. Project Cost Summary

(\$M)

2.1. Project Cost Summary			
Cost Category	PTF	Non-PTF	Total
Material	\$ 12.612	\$ -	\$ 12.612
Labor & Equipment	\$ 12.080	\$ -	\$ 12.080
Right of Way	\$ -	\$ -	\$ -
Engineering/Permitting /Indirects	\$ 2.775	\$ -	\$ 2.775
Escalation	\$ 0.838	\$ -	\$ 0.838
AFUDC	\$ 1.681	\$ -	\$ 1.681
Contingency	\$ 3.463	\$ -	\$ 3.463
Total Project Cost	\$ 33.449	\$ -	\$ 33.449

- Material
- Labor & Equipment
- Right of Way
- Engineering/Permitting /Indirects
- Escalation
- AFUDC
- Contingency



2.2 Detailed Cost Summary By Project Element

	Material	Labor & Equipment	Right of Way	Engineering/Permitting/ Indirects	Escalation	AFUDC	Contingency	Total	PTF Amount
NH 2029 Solution Central - 115-kV Huckins Hill Synchronous Condenser Project	\$ 12.612	\$ 12.080	\$ -	\$ 2.775	\$ 0.838	\$ 1.681	\$ 3.463	\$ 33.449	\$ 33.449
Total	\$ 12.612	\$ 12.080	\$ -	\$ 2.775	\$ 0.838	\$ 1.681	\$ 3.463	\$ 33.449	\$ 33.449

3. Project Milestone Schedule

Description	Start	Complete	2020				2021				2022				2023				2024				2025				2026			
			Qtr1	Qtr2	Qtr3	Qtr4	Qtr1	Qtr2	Qtr3	Qtr4	Qtr1	Qtr2	Qtr3	Qtr4	Qtr1	Qtr2	Qtr3	Qtr4	Qtr1	Qtr2	Qtr3	Qtr4	Qtr1	Qtr2	Qtr3	Qtr4	Qtr1	Qtr2	Qtr3	Qtr4
			Siting & Permitting																											
Approval and Permits	11/1/2020	3/31/2022																												
Engineering																														
Engineering and Design	11/1/2020	3/31/2023																												
Land																														
Material	2/1/2022	12/31/2022																												
Construction																														
Construction	7/1/2022	12/31/2023																												

NH 2029 Solution - Central Correlation Table
Huckins Hill Synchronous Condenser Project

<u>TCA Item</u>	<u>RSP:</u> Project ID #	<u>Study:</u> Reliability Issues Requiring <u>Action</u>	<u>PPA Application:</u>		<u>PAC/RC Meeting:</u> Presentation Reference	<u>TCA Application (\$1,000s):</u>	
			<u>PPA No.</u>	<u>Preferred Solution Description</u>		<u>PTF Estimate</u>	<u>Non-PTF Estimate</u>
ES-22-TCA-04	<u>1879</u>	n/a	ES-22-T28	NH 2029 Solution Central - Install one +50/-25 MVAR Synchronous Condenser and one 115-kV breaker at the Huckins Hill 115-kV substation.	Per PAC Presentation 02/17/2021 RC PPA approval 6/15/2022	\$ 33.449	
				SUBTOTAL		\$ 33.449	\$ -