

1231/1242 Reconductor and Structure Replacements

TCA Submittal Presentation
ES-22-TCA-29

NEPOOL Reliability Committee Meeting

August 15th, 2023


Agenda

- Project Background
- Drivers
- Location
- Summary


Project Background

- This presentation covers an asset condition project on the 115kV 1231/1242 Lines from Berkshire Substation to Cumberland Substation (1231) and Montague Substation(1242) in Western Massachusetts
- PAC History
 - Eversource Copper Conductor and Shield Wire Replacement - [January 2021](#)
 - Eversource 1231/1242 Line Reconductor and Structure Replacements - [August 2022](#) (Project update)
- Project Drivers
 - Inspections have identified thermal and environmental degradation of copper conductor and shield wire. Recent tests have also identified loss of strength in copper materials.
 - Aging lattice towers with structural deterioration and missing/broken equipment
- Replacing the deteriorated structures, obsolete copper conductor/shield wire, and installing OPGW is the most cost-effective option to address the potential for system failures due to asset condition vulnerabilities
- Replacing the original 2/0 copper conductor with 1272 kcmil ACSS utilizes a larger standard conductor yielding added system reliability and is the most efficient solution within the right of way
- The addition of OPGW expands the Eversource OPGW / Synchronous Optical Networking (SONET) loop

1231/1242 Geographic Location



Tower Failure - 2023



Buckled Damaged Lattice Tower
March 14, 2023



New Dual Circuit Monopole
March 29, 2023

Summary

- Replace 213 existing transmission structures and remove 17 midspan structures
- Replace existing 2/0 copper conductor with 1272 kcmil ACSS
 - 51.62 miles (25.81 miles per line) between Berkshire and Cumberland substations on 1231 and 1242 lines
- Replace existing copperweld/alumoweld shield wire with OPGW
 - 25.81 miles between Berkshire and Cumberland substations on 1231 line
 - 28.65 miles between Berkshire and Montague substations on 1242 line
- Terminal structure replacements and ADSS installation at line terminal substations
 - Will not be seeking cost regionalization for non-PTF substation work

Total estimated PTF Cost: \$158.5M

- Total Estimated Costs: \$171.6M, includes estimated NonPTF costs of \$13.1M

In-service Date: December 2024

Questions

